



#### GENERAL NOTES

- COORDINATE EXACT PLACEMENT OF ALL DEVICES WITH ARCHITECTURAL DRAWINGS AND PROPOSED TENANT DRAWINGS.
- PROVIDE UNSWITCHED CONDUCTORS TO EMERGENCY BALLASTS IN EMERGENCY/EXIT FIXTURES.

#### KEY NOTES

- COMBINATION EXIT/EMERGENCY FIXTURE: LITHONIA LHQM-LED-R-HO.
- RECESSED 2'X4' FIXTURE: LITHONIA 2SP8-6-2-32-A12125-MVOLT-GE810IS. PROVIDE WITH EMERGENCY BATTERY BALLAST WHERE SHOWN SHADED.
- DECORATIVE SCONCE: ALUMILITE YRW-2-20WLED-35K. PROVIDE FIXTURE WITH DOWNWARD OPTICS ONLY.
- EXTERIOR SCONCE: TECH LIGHTING LHSWP-1-N-2-T3-H-1; LHSWPBBU.
- ROUTE CIRCUIT THROUGH LIGHTING CONTACTOR. CONTACTOR SHALL BE CONTROLLED BY TIMECLOCK. TIMECLOCK SHALL BE 24 HOUR 7 DAY WITH CARRYOVER; INTERMATIC ET1705C SERIES OR EQUAL BY PARAGON OR TORK. PROVIDE WITH PHOTOCELL. LOCATE TIMECLOCK ADJACENT TO HOUSE PANEL.
- PROVIDE FIXTURE WITH EMERGENCY REMOTE HEAD. COORDINATE EXACT LOCATION OF EMERGENCY HEAD WITH ARCHITECTURAL ELEVATIONS.
- PROVIDE CONNECTION TO SIGNAGE FIXTURES. COORDINATE EXACT LOCATION AND SPECIFICATION WITH TENANT.

Christian Aybar, PE  
South Carolina PE #32116  
caybar@bestengineeringolutions.com  
404-457-7302



#### NEW RETAIL BUILDING KITTIES CROSSING

21 BLUFFTON ROAD  
BLUFFTON, SC 29910

ISSUE NUMBER #1 03/14/17

REVISIONS:

ISSUED: 03/10/2017

Floor Plan -  
Lighting

E100

Project: 17-130

Issued for Permit and Construction